

KNOWN ASBESTOS LOCATIONS AT SFSU

ASBESTOS LOCATIONS AT SFSU

as of 6/2024

ASBESTOS LOCATIONS AT SFSU as of 6/2024	ASBESTOS CONTAINING MATERIAL?	Some asbestos floor tiles	Asbestos pipe insulation on hot water, steam, or condensate lines in building electrical & mechanical rooms	Asbestos treated insulation on hot water storage tanks, Boilers, kilns, ducts, exhaust stacks	Rough Ceiling-Second floor classroom wing	Asbestos pipe lagging above ceiling	Rough Ceilings - Maintenance Shops	Rough Ceilings - Elevator lobbies, main corridors, 3rd floor hallways	Sprayed on asbestos fire proofing material above false ceilings -entire bldg.	Basement and First Floor: Vinyl 9x9 and 12x12 Floor Tiles and Mastics, Cove Mastic, Black/Yellow Carpet Glue
WHERE / WHAT BUILDING?										
Administration	YES	YES	YES							YES
Boiler plant (in Gymnasium)	YES	YES	YES	YES						
Burk Hall	YES	YES	YES							
Business	YES	YES	YES							
Creative Arts	YES	YES	YES		YES					
Field House 1 Cox Stadium	YES	YES	YES							
Field House 2 Maloney Field	YES	YES	YES			YES				
Gymnasium	YES	YES	YES							
Hensill Hall	YES	YES	YES				YES	YES		
HSS	YES	YES	YES							
Mary Park Hall	YES	YES	YES	YES						
Mary Ward Hall	YES	YES	YES	YES						
Psychology/Ethnic Studies	YES	YES	YES							
Residence Dining	YES	YES	YES							
Science Bldg.	YES	YES	YES							
Seven Hills	YES	YES	YES	YES						
Thornton Hall	YES	YES	YES							
University Park North	YES	YES	YES	YES		YES				
University Park South	YES	YES	YES	YES		YES				

**ASBESTOS
LOCATIONS
AT
Romberg Tiburon Center**

as of 6/2024

		Flooring	Pipe Insulation	Window Putty	Siding	Roofing / Roof Tiles	Boiler	Joint Compound
as of 6/2024	YES					~		~
Building #21	YES		Y	Y	Y			
Building #30 Leased to tenant	YES	Y	Y		Y			
Building #33	YES	Y	Y	Y				
Building #36 Research and Education	YES		Y	Y				
Building #37	YES	Y	Y	Y		Y		
Building #39 RTC Administration	YES	Y	Y		Y		Y	
Building #49	YES		Y	Y			Y	
Building #50	YES		Y	Y			Y	
Building #53 Bay Conference Center & Residence	YES		Y	Y	Y			
Building #54	YES	Y	Y	Y	Y			
Building #22	NO							
Building #74	NO							

**ASBESTOS
LOCATIONS
AT
Staff Cabin Sierra Nevada Field
Campus**

as of 6/2024

		Flooring	Joint Compound	Window Putty	Siding	Roofing / Roof Tiles	Boiler	Pipe Insulation
Wall and Ceiling Joint Compound– Throughout Building.	YES		Y					
9"x9" Floor Tile (red/brown)Under Tan/Yellow Stick-on Floor Tile in 1st Floor East Bedroom.	YES	Y						
Wall and Ceiling Texture (Smooth) and Drywall – Throughout Building.	NO							
12"x12" Floor Tile (Tan/yellow stick on) & Mastic – 1st Floor Bedrooms & Common Area.	NO							
Sheet Flooring (6"x6" slate) and Mastic – First Floor Restrooms.	NO							
Window Putty – Interior and Exterior original Windows Throughout Building.	NO							
Black Flooring Mastic – Under 9"x9" ACM Floor Tile in First Floor East Bedroom	NO							