

Air Compressors

- **Inspection Requirements:**

Cal/OSHA requires a permit if the air compressor tank is 1.5 cubic feet in volume or larger, OR when the safety valve is set greater than 150 pounds per square inch

(psi). *(Tanks with less than 1.5 cubic feet of air AND less than 150 psi ARE EXEMPT.)* Cal/OSHA requires air tanks requiring a permit to operate to be inspected internally and externally at least once every 3 years for portable tanks and once every 5 years for all other tanks.

SFSU has 29 air tanks that require a permit to operate.

- **FY 21-22 Update:**

Air tank permits and inspections are up to date for FY 21-22

