

KNOWN ASBESTOS LOCATIONS AT SFSU

[illegible]

ASBESTOS LOCATIONS AT SFSU as of 7/15/2025		ASBESTOS CONTAINING MATERIAL?	Some asbestos floor tiles	Asbestos pipe insulation on hot water, steam, or condensate lines in building electrical & mechanical rooms	Asbestos treated insulation on hot water storage tanks, Boilers, kilns, ducts, exhaust stacks	Rough Ceiling-Second floor classroom wing	Asbestos pipe lagging above ceiling	Rough Ceilings - Maintenance Shops	Rough Ceilings - Elevator lobbies, main corridors, 3rd floor hallways	Sprayed on asbestos fire proofing material above false ceilings -entire bldg.
WHERE / WHAT BUILDING?										
A.S Early Children's Center	NO									
Annex 1	NO									
Annex 2	NO									
C. Chavez Student Center	NO									
Central Plant	NO									
Children's Campus	NO									
COSE Trailers	NO									
Facilities & Capital Planning	NO									
Gator Student Health Center/Yerba Buena Dining Hall (West Campus Green Dining and Health Building)	NO									
Greenhouse 1	NO									
Greenhouse 2	NO									
HazMat Shed #1	NO									
HazMat Shed #2	NO									
Humanities	NO									
Library	NO									
Manzanita Square	NO									
Marcus Hall	NO									
Mashouf Wellness Center	NO									
Parking & Transportation	NO									
Parking Garage	NO									
Police Dept.	NO									
Procurement & Support Services	NO									
Recycling/Resource Center	NO									
Science and Engineering Innovation Center	NO									
Student Health Services	NO									
Student Services Bldg.	NO									
The Towers	NO									
The Village	NO									
West Grove Commons (West Campus Green Student Housing)	NO									
ASBESTOS LOCATIONS AT Romberg Tiburon Center as of 7/15/2025			Flooring	Pipe Insulation	Window Putty	Siding	Roofing / Roof Tiles	Boiler	Joint Compound	
as of 6/2024	YES						?		?	
Building #21	YES			Y	Y	Y				
Building #22	YES			Y	Y		Y		Y	

Building #30 Leased to tenant	YES	Y	Y		Y			
Building #33	YES	Y	Y	Y				
Building #36 Research and Education	YES		Y	Y				
Building #37	YES	Y	Y	Y		Y		
Building #39 RTC Administration	YES	Y	Y		Y		Y	
Building #49	YES		Y	Y			Y	
Building #50	YES		Y	Y			Y	
Building #53 Bay Conference Center & Residence	YES		Y	Y	Y			
Building #54	YES	Y	Y	Y	Y			
Building #74	YES		Y	Y		Y		Y
ASBESTOS LOCATIONS IN Sierra Nevada Field Campus Buildings as of 7/15/2025		Flooring	Joint Compound	Window Putty	Siding	Roofing / Roof Tiles	Boiler	Pipe Insulation
Wall and Ceiling Joint Compound– Throughout Building.	YES		Y					
9"x9" Floor Tile (red/brown)Under Tan/Yellow Stick-on Floor Tile in 1st Floor East Bedroom.	YES	Y						
Window Putty – Interior and Exterior original Windows Throughout Building.	YES			Y				
Wall and Ceiling Texture (Smooth) and Drywall – Throughout Building.	YES							
12"x12" Floor Tile (Tan/yellow stick on) & Mastic – 1st Floor Bedrooms & Common Area.	NO							
Sheet Flooring (6"x6" slate) and Mastic – First Floor Restrooms.	NO							
Black Flooring Mastic – Under 9"x9"ACM Floor Tile in First Floor East Bedroom	NO							